Notice and Necessary Information



Facility Name: Orange County Sanitation District Reclamation Plant #1, Fountain Valley, CA and Treatment Plant #2, Huntington Beach, CA

Monitoring Period: August 1- 31, 2015



Pollutant and Nitrogen concentrations (report results may be averages on 100% dry weight basis).

	As (mg/kg)	Cd (mg/kg)	Cu (mg/kg)	Pb (mg/kg)	Hg (mg/kg)	Mo (mg/kg)	Ni (mg/kg)	Se (mg/kg)	Zn (mg/kg)	Org-N (mg/kg)	Ammonia (mg/kg)	Cr (mg/kg)	% solids
Result Plant 1	9.8	4.4	440	<21	0.86	16	43	7.2	610	43,000	6,200	46	19
Result Plant 2	11	4.5	480	<19	0.79	18	34	<4.7	750	36,000	5,200	49	22
Table 3	41	39	1,500	300	17	N/A	420	100	2,800	N/A	N/A	N/A	N/A
Table 1	75	85	4,300	840	57	75	420	100	7,500	N/A	N/A	3,000	N/A

Class B Pathogen Reduction

Class B pathogen reduction requirements from 40 CFR part 503 and Arizona Administrative Code R18-9-1006-E have been met via anaerobic digestion under the following parameters

	Mean Re Time (Mean minimum Temperature (°F)					
	Min	Max	(All digesters)					
Plant 1	21	23	97 - 98					
Plant 2	19	22	96 - 100					

Vector Attraction Reduction

The vector attraction reduction requirements of 40 CFR part 503 and Arizona Administrative Code R18-9-1010. A have been met using data (may be averages) analyzed by an Arizona certified laboratory to comply with Option 1:

Sampling date(s): 08/05/2015,08/12/2015

	% Volatile Solids									
	In	Out	Reduction							
Plant 1	3.2	1.3	58.9							
Plant 2	3.6	1.5	57.8							

Certifications:

NPDES permit: I certify, under penalty of law, that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or the persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

503 Class B: I certify, under penalty of law, that the Class B pathogen requirements in 503.32(b) and the vector attraction reduction requirement in 503.33(b)(1) have been met. This determination has been made under my direction and supervision in accordance with the system designed to ensure that qualified personnel properly gather and evaluate the information used to determine that the pathogen requirements and vector attraction requirements have been met. I am aware that there are significant penalties for false certification including the possibility of fine and imprisonment.

Arizona Class B: I certify, under penalty of law, that the pollutant analyses and the description of pathogen treatment and vector attraction reduction activities have been made under my direction and supervision and under a system designed to ensure that qualified personnel properly gather and evaluate the information used to determine whether the applicable biosolids requirements have been met. I am aware that there are significant penalties for false certification including the possibility of fine and imprisonment

Signed by: Colston, Jim

12/2/2015 12/2/2015 11/12/2015

James Spears Operations Manager Signed by: Spears, Jim jspears@ocsd.com (714)593-7081

James E. Colston Env. Compliance Manager

jcolston@ocsd.com

(714) 593-7450

Ronald Coss Laboratory Manager

Signed by: Coss, Ronald

rcoss@ocsd.com (714)593-7508





Individual Digester Mean Cell Residence Times and Minimum Temperatures

Facility Name: Orange County Sanitation District Reclamation Plant #1, Fountain Valley, CA and Treatment Plant #2, Huntington Beach, CA

Monitoring Period: August 1- 31, 2015



OCSD Plant 1

	Dig. 7	Dig. 8	Dig. 9	Dig. 10	Dig. 11	Dig. 12	Dig. 13	Dig. 14	Dig. 15	Dig. 16
Minimum Mean Cell Residence Time (days)*	21	21	21	21		20	21	21		
Minimum Temperature (°F)	98	98	97	98		98	98	98		

Shaded box represents Digester is Out of Service.

OCSD Plant 2

	Dig. C	Dig. D	Dig. E	Dig. F	Dig. G	Dig. H	Dig. L	Dig. M	Dig. N	Dig. O	Dig. P	Dig. Q	Dig. R	Dig. S	Dig. T	Dig. I	Dig. J
Minimum Mean Cell Residence Time (days)*	18	19	18	20	20	20	17	20	18	19	19		20	20	18	46	22
Minimum Temperature (°F)	96	99	98	100	100	97	97	96	98	98	98		99	98	99	99	99

Shaded box represents Digester is Out of Service.

Significant Events:

In August 2015, we discovered a calculation error in the Monthly Summary of Operations (MSO) for OCSD Plant 2 that affected the digester mean cell residence times (MCRT) if a digester was brought into or taken out of service during the month. The error has been corrected and the digester MCRTs recalculated for January – June 2015; the correction was applied to the July MSO. Although some values changed, no values dropped below the minimum 15 day MCRT, so compliance was not impacted.

^{*}MCRT based on a 15-Day Rolling Average.

^{*}MCRT based on a 15-Day Rolling Average.