



## Biosolids Monthly Compliance Report

**Facility Name:** Orange County Sanitation District Reclamation Plant #1, Fountain Valley, CA and Treatment Plant #2, Huntington Beach, CA

**Monitoring Period:** July 1- 31, 2017

This notice and necessary information demonstrates compliance with requirements of the Code of Federal Regulations Title 40 Part 503 and the Arizona Administrative Code Title 18, Chapter 9, Article 10 for land application pollutant concentrations, Class B pathogen reduction via anaerobic digestion (40CFR 503.32(b)(3)(A)(3), AAC R18-9-1006(E)(5)), and vector attraction reduction via volatile solids reduction (40CFR 503.33(b)(1), AAC R18-9-1010(A)(1)).

**Sampling date(s):** 07/06/17,07/12/17

	Mercury (mg/kg dry)	Arsenic (mg/kg dry)	Cadmium (mg/kg dry)	Chromium (mg/kg dry)	Copper (mg/kg dry)	Lead (mg/kg dry)	Molybdenum (mg/kg dry)	Nickel (mg/kg dry)	Selenium (mg/kg dry)	Zinc (mg/kg dry)	Ammonia Nitrogen (mg/kg dry)	Organic Nitrogen (mg/kg dry)	Total Nitrogen (mg/kg dry)	pH	Total Solids (%)	VSR (%)
<b>Plant 1 Max/Min<sup>1</sup></b>	1.1	7.4	5.2	37	430	12	15	34	6.5	650	6,200	43,000	49,000	8.1	17	51
<b>Plant 1 Avg</b>	0.92	7.2	4.4	36	430	10 DNQ	14	34	6.2	650	6,100	43,000	49,000		18	
<b>Plant 2 Avg</b>	0.76	8.7	4.5	53	480	10	15	33	7.9	730	5,300	42,000	47,000		21	
<b>Plant 2 Max/Min<sup>1</sup></b>	0.82	9.6	5.1	58	490	11	15	34	9.7	750	5,300	42,000	47,000	8.1	21	65
<b>Table 1 (Max/Min*)</b>	57	75	85	3000	4300	840	75	420	100	7500	N/A	N/A	N/A	6.5	15	38
<b>Table 3 (Avg)</b>	17	41	39	N/A	1500	300	N/A	420	100	2800	N/A	N/A	N/A	N/A	N/A	N/A

<b>OCSD Plant 1</b>	<b>System Summary</b>	<b>Dig. 7</b>	<b>Dig. 8</b>	<b>Dig. 9</b>	<b>Dig. 10</b>	<b>Dig. 11</b>	<b>Dig. 12</b>	<b>Dig. 13</b>	<b>Dig. 14</b>	<b>Dig. 15</b>	<b>Dig. 16</b>
<b>Minimum Mean Cell Residence Time (Min 15 days)<sup>2</sup></b>	23	21	21	21	21	21	70 <sup>3</sup>	21	Out of Service	21	21
<b>Minimum Mean Cell Residence Time (Min 95 °F)</b>	98	100	100	100	100	100	98	100	Out of Service	100	100

<b>OCSD Plant 2</b>	<b>System Summary</b>	<b>Dig. C</b>	<b>Dig. D</b>	<b>Dig. E</b>	<b>Dig. F</b>	<b>Dig. G</b>	<b>Dig. H</b>	<b>Dig. I</b>	<b>Dig. J</b>	<b>Dig. L</b>	<b>Dig. M</b>	<b>Dig. N</b>	<b>Dig. O</b>	<b>Dig. P</b>	<b>Dig. Q</b>	<b>Dig. R</b>	<b>Dig. S</b>	<b>Dig. T</b>
<b>Minimum Mean Cell Residence Time (Min 15 days)<sup>2</sup></b>	19	19	18	Out of Service	19	19	Out of Service	18	19	20	Out of Service	19	19	19	19	18	19	19
<b>Minimum Temperature (Min 95 °F)</b>	99	99	100	Out of Service	100	100	Out of Service	99	99	99	Out of Service	100	100	99	100	100	99	100

DNQ (Detected, Not Quantified) represents estimated values above the method detection limit (MDL), but below the reporting limit (RL).

<sup>1</sup> Maximum values are reported for metals and nitrogen parameters; minimum values are reported for pH, volatile solids reduction (VSR) and total solids. Analysis of pH is conducted to comply with AAC R18-9-1007(A)(1). The limit for total solids applies only if biosolids are sent to a California landfill, per CCR Title 27 Section 20220(c)(3).

<sup>2</sup> MCRT based on a 15-Day Rolling Average.

<sup>3</sup> Digester 12 was brought into service on July 11, 2017.



## Biosolids Monthly Compliance Report

**Facility Name:** Orange County Sanitation District Reclamation Plant #1, Fountain Valley, CA and Treatment Plant #2, Huntington Beach, CA

**Monitoring Period:** July 1- 31, 2017

### Certifications:

**NPDES permit:** *I certify, under penalty of law, that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or the persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.*

**503 Class B:** *I certify, under penalty of law, that the Class B pathogen requirements in 503.32(b) and the vector attraction reduction requirement in 503.33(b)(1) have been met. This determination has been made under my direction and supervision in accordance with the system designed to ensure that qualified personnel properly gather and evaluate the information used to determine that the pathogen requirements and vector attraction requirements have been met. I am aware that there are significant penalties for false certification including the possibility of fine and imprisonment.*

**Arizona Class B:** *I certify, under penalty of law, that the pollutant analyses and the description of pathogen treatment and vector attraction reduction activities have been made under my direction and supervision and under a system designed to ensure that qualified personnel properly gather and evaluate the information used to determine whether the applicable biosolids requirements have been met. I am aware that there are significant penalties for false certification including the possibility of fine and imprisonment.*

X 

---

James Spears                      jspears@ocsd.com  
Operations Manager              (714)593-7081  
Signed by: Spears, Jim

X 

---

Ronald Coss                      rcoss@ocsd.com  
Lab, Mon. & Compliance Mgr      (714)593-7508  
Signed by: Coss, Ronald