



Biosolids Monthly Compliance Report

Facility Name: Orange County Sanitation District Reclamation Plant #1, Fountain Valley, CA and Treatment Plant #2, Huntington Beach, CA

Monitoring Period: October 1- 31, 2018

This notice and necessary information demonstrates compliance with requirements of the Code of Federal Regulations Title 40 Part 503 and the Arizona Administrative Code Title 18, Chapter 9, Article 10 for land application pollutant concentrations, Class B pathogen reduction via anaerobic digestion (40CFR 503.32(b)(3)(A)(3), AAC R18-9-1006(E)(5)), and vector attraction reduction via volatile solids reduction (40CFR 503.33(b)(1), AAC R18-9-1010(A)(1)).

Sampling date(s): 10/16/18,10/23/18

	Mercury (mg/kg dry)	Arsenic (mg/kg dry)	Cadmium (mg/kg dry)	Chromium (mg/kg dry)	Copper (mg/kg dry)	Lead (mg/kg dry)	Molybdenum (mg/kg dry)	Nickel (mg/kg dry)	Selenium (mg/kg dry)	Zinc (mg/kg dry)	Ammonia Nitrogen (mg/kg dry)	Organic Nitrogen (mg/kg dry)	Total Nitrogen (mg/kg dry)	pH	Total Solids (%)	VSR (%)
Plant 1 Max/Min*	1.0	29	4.4	76	610	19	22	47	<3.1	950	6,600	53,000	60,000	7.8	18	54
Plant 1 Avg	0.86	24	3.0 DNQ	58	510	15	18	38	<3.1	760	6,300	51,000	57,000		19	
Plant 2 Max/Min*	0.82	24	3.7	57	550	16	19	41	<2.7	810	5,900	47,000	53,000	7.8	20	53
Plant 2 Avg	0.81	24	2.7 DNQ	52	520	15	19	39	<2.7	760	5,700	46,000	51,000		21	
Table 1 (Max/Min)*	57	75	85	3000	4300	840	75	420	100	7500	N/A	N/A	N/A	6.5	15	38
Table 3 (Avg)	17	41	39	N/A	1500	300	N/A	420	100	2800	N/A	N/A	N/A	N/A	N/A	N/A

OCSD Plant 1	System Summary	Dig. 7	Dig. 8	Dig. 9	Dig. 10	Dig. 11	Dig. 12	Dig. 13	Dig. 14	Dig. 15	Dig. 16
Minimum Mean Cell Residence Time (Min 15 days)**	21	Out of Service	Out of Service	20	20	21	21	21	21	21	21
Minimum Temperature (Min 95 °F)	98	Out of Service	Out of Service	98	98	98	98	98	98	98	98

OCSD Plant 2	System Summary	Dig. C	Dig. D	Dig. E	Dig. F	Dig. G	Dig. H	Dig. I	Dig. J	Dig. L	Dig. M	Dig. N	Dig. O	Dig. P	Dig. Q	Dig. R	Dig. S	Dig. T
Minimum Mean Cell Residence Time (Min 15 days)**	19	21	19	Out of Service	19	19	Out of Service	18	19	18	19	18	19	Out of Service	20	20	19	22
Minimum Temperature (Min 95 °F)	98	98	99	Out of Service	99	99	Out of Service	99	100	98	99	100	99	Out of Service	100	100	99	99

DNQ (Detected, Not Quantified) represents estimated values above the method detection limit (MDL), but below the reporting limit (RL).

* Maximum values are reported for metals and nitrogen parameters; minimum values are reported for pH, volatile solids reduction (VSR) and total solids. Analysis of pH is conducted to comply with AAC R18-9-1007(A)(1). The limit for total solids applies only if biosolids are sent to a California landfill, per CCR Title 27 Section 20220(c)(3).

** MCRT based on a 15-Day Rolling Average.



Biosolids Monthly Compliance Report

Facility Name: Orange County Sanitation District Reclamation Plant #1, Fountain Valley, CA and Treatment Plant #2, Huntington Beach, CA

Monitoring Period: October 1- 31, 2018

Certifications:

NPDES permit: *I certify, under penalty of law, that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or the persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.*

503 Class B: *I certify, under penalty of law, that the Class B pathogen requirements in 503.32(b) and the vector attraction reduction requirement in 503.33(b)(1) have been met. This determination has been made under my direction and supervision in accordance with the system designed to ensure that qualified personnel properly gather and evaluate the information used to determine that the pathogen requirements and vector attraction requirements have been met. I am aware that there are significant penalties for false certification including the possibility of fine and imprisonment.*

Arizona Class B: *I certify, under penalty of law, that the pollutant analyses and the description of pathogen treatment and vector attraction reduction activities have been made under my direction and supervision and under a system designed to ensure that qualified personnel properly gather and evaluate the information used to determine whether the applicable biosolids requirements have been met. I am aware that there are significant penalties for false certification including the possibility of fine and imprisonment.*

Jim Spears
Operations Manager

jspears@ocsd.com
(714) 593-7081

Ron Coss
Laboratory, Monitoring &
Compliance Manager

rcoss@ocsd.com
(714) 593-7508

Cindy Vellucci (Jan 11, 2019)

Deirdre Bingman

Rachel van Exel

Peter Park (Jan 14, 2019)

Margil Jimenez (Jan 15, 2019)












2018-10_Biosolids_Compliance_Report

Final Audit Report

2019-01-15

Created:	2019-01-11
By:	Cindy Vellucci (cvellucci@ocsd.com)
Status:	Signed
Transaction ID:	CBJCHBCAABAAAUbXUqWDOPjPUMY6JHvIP4Om34VNQh7N

"2018-10_Biosolids_Compliance_Report" History


-  Document uploaded by Cindy Vellucci (cvellucci@ocsd.com) from Acrobat
2019-01-11 - 6:06:51 PM GMT- IP address: 206.169.97.226
-  Document signed in Acrobat by Cindy Vellucci (cvellucci@ocsd.com)
Signature Date: 2019-01-11 - 6:10:59 PM GMT - Time Source: server- IP address: 206.169.97.226
-  Document emailed to Deirdre Bingman (dbingman@ocsd.com) for signature
2019-01-11 - 6:10:59 PM GMT
-  Document e-signed by Deirdre Bingman (dbingman@ocsd.com)
E-signature obtained using URL retrieved through the Adobe Sign API
Signature Date: 2019-01-11 - 6:12:26 PM GMT - Time Source: server- IP address: 206.169.97.226
-  Document emailed to Rachel Van Exel (rvanexel@ocsd.com) for signature
2019-01-11 - 6:12:27 PM GMT
-  Document viewed by Rachel Van Exel (rvanexel@ocsd.com)
2019-01-14 - 5:43:54 PM GMT- IP address: 206.169.97.226
-  Document e-signed by Rachel Van Exel (rvanexel@ocsd.com)
Signature Date: 2019-01-14 - 7:10:56 PM GMT - Time Source: server- IP address: 206.169.97.226
-  Document emailed to Peter Park (ppark@ocsd.com) for signature
2019-01-14 - 7:10:56 PM GMT
-  Document viewed by Peter Park (ppark@ocsd.com)
2019-01-14 - 7:12:12 PM GMT- IP address: 206.169.97.226
-  Document e-signed by Peter Park (ppark@ocsd.com)
Signature Date: 2019-01-14 - 8:40:51 PM GMT - Time Source: server- IP address: 206.169.97.226
-  Document emailed to Margil Jimenez (mjjimenez@ocsd.com) for signature
2019-01-14 - 8:40:51 PM GMT

 Document viewed by Margil Jimenez (mjjimenez@ocsd.com)


2019-01-14 - 9:30:27 PM GMT- IP address: 206.169.97.226

 Document e-signed by Margil Jimenez (mjjimenez@ocsd.com)


Signature Date: 2019-01-15 - 3:39:06 PM GMT - Time Source: server- IP address: 206.169.97.226

 Document emailed to Jim Spears (jspears@ocsd.com) for signature


2019-01-15 - 3:39:06 PM GMT

 Document viewed by Jim Spears (jspears@ocsd.com)

2019-01-15 - 7:12:47 PM GMT- IP address: 206.169.97.226

 Document e-signed by Jim Spears (jspears@ocsd.com)

Signature Date: 2019-01-15 - 7:14:27 PM GMT - Time Source: server- IP address: 206.169.97.226

 Document emailed to Ron Coss (rcoss@ocsd.com) for signature

2019-01-15 - 7:14:27 PM GMT

 Document viewed by Ron Coss (rcoss@ocsd.com)

2019-01-15 - 9:52:15 PM GMT- IP address: 206.169.97.226

 Document e-signed by Ron Coss (rcoss@ocsd.com)

Signature Date: 2019-01-15 - 9:53:56 PM GMT - Time Source: server- IP address: 206.169.97.226

 Signed document emailed to Peter Park (ppark@ocsd.com), Jim Spears (jspears@ocsd.com), Margil Jimenez (mjjimenez@ocsd.com), Deirdre Bingman (dbingman@ocsd.com), and 3 more

2019-01-15 - 9:53:56 PM GMT