



Biosolids Monthly Compliance Report

Facility Name: Orange County Sanitation District Reclamation Plant #1, Fountain Valley, CA and Treatment Plant #2, Huntington Beach, CA

Monitoring Period: July 1- 31, 2020

This notice and necessary information demonstrates compliance with requirements of the Code of Federal Regulations Title 40 Part 503 and the Arizona Administrative Code Title 18, Chapter 9, Article 10 for land application pollutant concentrations, Class B pathogen reduction via anaerobic digestion (40CFR 503.32(b)(3)(A)(3), AAC R18-9-1006(E)(5)), and vector attraction reduction via volatile solids reduction (40CFR 503.33(b)(1), AAC R18-9-1010(A)(1)).

Sampling date(s): 07/21/2020, 07/28/2020

	Mercury (mg/kg dry)	Arsenic (mg/kg dry)	Cadmium (mg/kg dry)	Chromium (mg/kg dry)	Copper (mg/kg dry)	Lead (mg/kg dry)	Molybdenum (mg/kg dry)	Nickel (mg/kg dry)	Selenium (mg/kg dry)	Zinc (mg/kg dry)	Ammonia Nitrogen (mg/kg dry)	Organic Nitrogen (mg/kg dry)	Total Nitrogen (mg/kg dry)	pH	Total Solids (%)	VSR (%)
Plant 1 Max/Min*	0.54	<1.3	1.7	51	540	15	20	37	<0.95	820	8,400	47,000	55,000	8.2	25	64
Plant 1 Avg	0.49	<1.3	1.6	51	540	15	20	35	<0.95	790	8,200	46,000	54,000		25	
Plant 2 Max/Min*	0.49	<1.2	2.4	66	540	18	21	33	<0.87	770	4,700	46,000	51,000	8.2	27	71
Plant 2 Avg	0.47	<1.2	2.4	65	520	18	20	32	<0.87	770	4,700	45,000	50,000		28	
Table 1 (Max/Min)*	57	75	85	3000	4300	840	75	420	100	7500	N/A	N/A	N/A	6.5	15	38
Table 3 (Avg)	17	41	39	N/A	1500	300	N/A	420	100	2800	N/A	N/A	N/A	N/A	N/A	N/A

OCSD Plant 1	System Summary	Dig. 7	Dig. 8	Dig. 9	Dig. 10	Dig. 11	Dig. 12	Dig. 13	Dig. 14	Dig. 15	Dig. 16
Minimum Mean Cell Residence Time (Min 15 days)**	25	26	26	Out of Service	24	25	25	25	26	25	25
Minimum Temperature (Min 95 °F)	97	98	98	Out of Service	98	98	98	98	98	97	98

OCSD Plant 2	System Summary	Dig. C	Dig. D	Dig. E	Dig. F	Dig. G	Dig. H	Dig. I	Dig. J	Dig. L	Dig. M	Dig. N	Dig. O	Dig. P	Dig. Q	Dig. R	Dig. S	Dig. T
Minimum Mean Cell Residence Time (Min 15 days)**	26	28	Out of Service	29	Out of Service	22	22	Out of Service	Out of Service	28	28	22	Out of Service	28	28	28	Out of Service	23
Minimum Temperature (Min 95 °F)	97	100	Out of Service	97	Out of Service	101	100	Out of Service	Out of Service	100	100	99	Out of Service	99	100	100	Out of Service	101

DNQ (Detected, Not Quantified) represents estimated values above the method detection limit (MDL), but below the reporting limit (RL).

* Maximum values are reported for metals and nitrogen parameters; minimum values are reported for pH, volatile solids reduction (VSR) and total solids. Analysis of pH is conducted to comply with AAC R18-9-1007(A)(1). The limit for total solids applies only if biosolids are sent to a California landfill, per CCR Title 27 Section 20220(c)(3).

** MCRT based on a 15-Day Rolling Average.



Biosolids Monthly Compliance Report

Facility Name: Orange County Sanitation District Reclamation Plant #1, Fountain Valley, CA and Treatment Plant #2, Huntington Beach, CA

Monitoring Period: July 1- 31, 2020

Certifications:

NPDES permit: I certify, under penalty of law, that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or the persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

503 Class B: I certify, under penalty of law, that the Class B pathogen requirements in 503.32(b) and the vector attraction reduction requirement in 503.33(b)(1) have been met. This determination has been made under my direction and supervision in accordance with the system designed to ensure that qualified personnel properly gather and evaluate the information used to determine that the pathogen requirements and vector attraction requirements have been met. I am aware that there are significant penalties for false certification including the possibility of fine and imprisonment.

Arizona Class B: I certify, under penalty of law, that the pollutant analyses and the description of pathogen treatment and vector attraction reduction activities have been made under my direction and supervision and under a system designed to ensure that qualified personnel properly gather and evaluate the information used to determine whether the applicable biosolids requirements have been met. I am aware that there are significant penalties for false certification including the possibility of fine and imprisonment.

Jim Spears
Operations Manager

jspears@ocsd.com
(714) 593-7081

Ron Coss
Laboratory, Monitoring &
Compliance Manager

rcoss@ocsd.com
(714) 593-7508

[Cindy Vellucci](#)
Cindy Vellucci (Sep 17, 2020 13:17 PDT)

Cindy Vellucci

[Deirdre Bingman](#)
Deirdre Bingman (Sep 17, 2020 13:53 PDT)

Deirdre Bingman

[Rachel Van Exel](#)

Rachel Van Exel

[Reza Sobhani](#)
Reza Sobhani (Sep 23, 2020 12:46 PDT)

Reza Sobhani

[Lan C. Wiborg](#)
Lan C. Wiborg (Sep 23, 2020 13:57 PDT)

Lan Wiborg