



Biosolids Monthly Compliance Report

Facility Name: Orange County Sanitation District Reclamation Plant #1, Fountain Valley, CA and Treatment Plant #2,

Monitoring Period: August 1- 31, 2021

This notice and necessary information demonstrates compliance with requirements of the Code of Federal Regulations Title 40 Part 503 and the Arizona Administrative Code Title 18, Chapter 9, Article 10 for land application pollutant concentrations, Class B pathogen reduction via anaerobic digestion (40CFR 503.32(b)(3)(A)(3), AAC R18-9-1006(E)(5)), and vector attraction reduction via volatile solids reduction (40CFR 503.33(b)(1), AAC R18-9-1010(A)(1)).

Sampling date(s): 08/03/21, 08/10/21

	Mercury (mg/kg dry)	Arsenic (mg/kg dry)	Cadmium (mg/kg dry)	Chromium (mg/kg dry)	Copper (mg/kg dry)	Lead (mg/kg dry)	Molybdenum (mg/kg dry)	Nickel (mg/kg dry)	Selenium (mg/kg dry)	Zinc (mg/kg dry)	Ammonia Nitrogen (mg/kg dry)	Organic Nitrogen (mg/kg dry)	Total Nitrogen (mg/kg dry)	pH	Total Solids (%)	VSR (%)
Plant 1 Max/Min*	0.73	9.0 DNQ	0.65	49	570	7.8	21	31	8.2	850	19,000	47,000	53,000	8.0	25	55
Plant 1 Avg	0.65	8.8 DNQ	0.63	49	550	7.2	20	31	7.8	840	13,000	37,000	49,000		25	
Plant 2 Max/Min*	0.58	11	1.2	43	430	5.8	20	27	8.0	720	10,000	42,000	51,000	7.9	28	67
Plant 2 Avg	0.51	10	1.1	42	400	4.7	19	25	7.5	690	7,400	42,000	49,000		28	
Table 1 (Max/Min)*	57	75	85	3000	4300	840	75	420	100	7500	N/A	N/A	N/A	6.5	15	38
Table 3 (Avg)	17	41	39	N/A	1500	300	N/A	420	100	2800	N/A	N/A	N/A	N/A	N/A	N/A

OCSD Plant 1	System Summary	Dig. 7	Dig. 8	Dig. 9	Dig. 10	Dig. 11	Dig. 12	Dig. 13	Dig. 14	Dig. 15	Dig. 16
Minimum Mean Cell Residence Time (Min 15 days)**	24	22	24	25	26	24	24	24	24	25	24
Minimum Temperature (Min 95 °F)	98	99	98	99	99	99	99	99	99	99	99

OCSD Plant 2	System Summary	Dig. C	Dig. D	Dig. E	Dig. F	Dig. G	Dig. H	Dig. I	Dig. J	Dig. L	Dig. M	Dig. N	Dig. O	Dig. P	Dig. Q	Dig. R	Dig. S	Dig. T
Minimum Mean Cell Residence Time (Min 15 days)**	27	Out of Service	Out of Service	26	Out of Service	28	28	Out of Service	Out of Service	26	26	28	Out of Service	27	27	28	Out of Service	28
Minimum Temperature (Min 95 °F)	97	Out of Service	Out of Service	100	Out of Service	100	100	Out of Service	Out of Service	100	97	98	Out of Service	100	99	100	Out of Service	100

DNQ (Detected, Not Quantified) represents estimated values above the method detection limit (MDL), but below the reporting limit (RL).

* Maximum values are reported for metals and nitrogen parameters; minimum values are reported for pH, volatile solids reduction (VSR) and total solids. Analysis of pH is conducted to comply with AAC R18-9-1007(A)(1). The limit for total solids applies only if biosolids are sent to a California landfill, per CCR Title 27 Section 20220(c)(3).

** MCRT based on a 15-Day Rolling Average.

Facility Name: Orange County Sanitation District Reclamation Plant #1, Fountain Valley, CA and Treatment Plant #2,

Monitoring Period: August 1- 31, 2021

Certifications:

NPDES permit: *I certify, under penalty of law, that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or the persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.*

503 Class B: *I certify, under penalty of law, that the Class B pathogen requirements in 503.32(b) and the vector attraction reduction requirement in 503.33(b)(1) have been met. This determination has been made under my direction and supervision in accordance with the system designed to ensure that qualified personnel properly gather and evaluate the information used to determine that the pathogen requirements and vector attraction requirements have been met. I am aware that there are significant penalties for false certification including the possibility of fine and imprisonment.*

Arizona Class B: *I certify, under penalty of law, that the pollutant analyses and the description of pathogen treatment and vector attraction reduction activities have been made under my direction and supervision and under a system designed to ensure that qualified personnel properly gather and evaluate the information used to determine whether the applicable biosolids requirements have been met. I am aware that there are significant penalties for false certification including the possibility of fine and imprisonment.*

Jim Spears

[Jim Spears \(Nov 30, 2021 14:44 PST\)](#)

Jim Spears
Operations Manager

jspears@ocsan.gov
(714) 593-7081

Lan Wiborg

[Lan Wiborg \(Nov 30, 2021 15:17 PST\)](#)

Lan C. Wiborg
Environmental Services Director

lwiborg@ocsan.gov
(714) 593-7540

Cindy Vellucci

[Cindy Vellucci \(Nov 29, 2021 16:37 PST\)](#)

Cindy Vellucci

Deirdre Bingman

[Deirdre Bingman \(Nov 30, 2021 09:28 PST\)](#)

Deirdre Bingman

Rachel Van Exel

Rachel Van Exel

Reza Sobhani

[Reza Sobhani \(Nov 30, 2021 11:12 PST\)](#)

Reza Sobhani